INAMINAL Series Expandable Power Systems Installation Guide

Models Include:

Maximal11FE

- Power Supply 1: 12VDC or 24VDC @ 4 amp.
- Power Supply 2: 12VDC or 24VDC @ 4 amp.

Maximal13FE

- Power Supply 1: 12VDC or 24VDC @ 4 amp.
- Power Supply 2: 12VDC or 24VDC @ 6 amp.

Maximal33FE

- Power Supply 1: 12VDC or 24VDC @ 6 amp.
- Power Supply 2: 12VDC or 24VDC @ 6 amp.

Maximal35FE

- Power Supply 1: 12VDC or 24VDC @ 6 amp.
- Power Supply 2: 12VDC @ 10 amp.

Maximal37FE

- Power Supply 1: 12VDC or 24VDC @ 6 amp.
- Power Supply 2: 24VDC @ 10 amp.

Maximal55FE

- Power Supply 1: 12VDC @ 10 amp.
- Power Supply 2: 12VDC @ 10 amp.

Maximal75FE

- Power Supply 1: 24VDC @ 10 amp.
- Power Supply 2: 12VDC @ 10 amp.

Maximal77FE

- Power Supply 1: 24VDC @ 10 amp.
- Power Supply 2: 24VDC @ 10 amp.





MaximalFE Overview:

Maximal Expandable Power Systems provide system designers and installers with optimum power choices and the highest levels of versatility. They provide 12VDC, 24VDC, or 12VDC and 24VDC simultaneously via two (2) single output power supply/chargers. Includes AC fail, low battery, and battery presence monitoring. Enclosure facilitates up to four (4) 12VDC/12AH batteries. All interconnecting equipment must be UL Listed.

MaximalFE Features:

Input:

• 120VAC, 60Hz.

Output:

- For output voltage and supply current, refer to *MaximalFE series Configuration Chart, pg. 3*.
- Auxiliary power-limited output rated @ 1 amp (unswitched).
- Overvoltage protection.

Battery Backup:

- Built-in charger for sealed lead acid or gel type batteries.
- Maximum charge current 1.54 amp.
- Automatic switch over to stand-by battery when AC fails. Transfer to stand-by battery power is instantaneous with no interruption.

Fire Alarm Disconnect:

• Supervised Fire Alarm disconnect (latching or non-latching) 10K EOL resistor. Operates on a normally open (NO) or normally closed (NC) trigger.

Supervision:

- AC fail supervision (form "C" contacts).
- Battery fail and presence supervision (form "C" contacts).
- Low power shutdown. Shuts down DC output terminals if battery voltage drops below 71-73% for 12V units and 70-75% for 24V units (depending on the power supply). Prevents deep battery discharge.

Fuse Ratings:

• Refer to MaximalFE series Configuration Chart, pg. 3.

Visual Indicators:

- Green AC Power LED indicates 120VAC present.
- AC input and DC output LED indicators.

Additional Features:

- Short circuit and overload protection.
- Unit is complete with power supply, enclosure, battery leads and cam lock.

Maximal11FE only: This unit is classified as Power-Limited stand alone power supply with stand-by battery and it is suitable to power sensors, electro-mechanical devices (e.g. electric door strikes).

Maximal13FE has one power-limited board (eFlow4NB) and one non power-limited (eFlow6NB).

*Maximal35FE, Maximal35FE, Maximal37FE, Maximal55FE, Maximal75FE, Maximal77FE: The DC output for these power supplies are not power-limited. If a power-limited output is required in the end-product application, the DC output from the power supply must be connected to a separately Listed control unit or accessory board that provides power-limited outputs. The product(s) providing the power-limited output(s) must be listed as appropriate for the particular end-product application (access control), and wired in accordance with the products installation instructions. Class 1 wiring methods, separation of circuits, and proper fire-rated enclosures all must be considered when connecting the DC output of the power supply to the end-product devices. The auxiliary outputs of these units are power-limited.

* UL Listings for US Installations:

UL 294 - UL Listed for Access Control System Units.

UL Listings for Canadian Installations:

ULC-S319-05 - Electronic Access Control Systems Class I equipment.

CSA C22.2 No.205 - Signal Equipment.

ULC-S319-05 Electronic Access Control Systems will be invalidated through the use of any add-on, expansion, memory or other module manufactured by the manufacturer or other manufacturers.

- 2 - Maximal Expandable Power Systems

MaximalFE Series Configuration Chart:

	Nominal DC Output Voltage Options										(dı		_			
	Power Supply 1			Power Supply 2				np)				(am	urd)	ard)		
	[D	[DC] [AUX]		J X]	[DC]		[Al	J X]	t fo	ıts		nts	Hz	Воя	Bos	_
Altronix Model Number	12VDC Output Range (volts)	24VDC Output Range (volts)	12VDC Output Range (volts)	24VDC Output Range (volts)	12VDC Output Range (volts)	24VDC Output Range (volts)	12VDC Output Range (volts)	24VDC Output Range (volts)	Maximum Supply Current for Main and Aux. Outputs (Power Supply 1/Power Supply 2) (amp)	Non Power-Limited Outputs	Power-Limited Outputs	Aux. Power-Limited Outputs	Input Rating: 120VAC 60Hz (amp)	Input Fuse Rating (per eFlow Power Supply Board)	Battery Fuse Rating (per eFlow Power Supply Board)	Ripple Voltage (mV) Under low battery condition
		eFlov				eFlov	v4NB									
	10.1- 13.2		10.05- 13.2		10.1- 13.2		10.05- 13.2				2	2	7	5A/ 250V	7.5A/32V	730
Maximal11FE	10.1- 13.2		10.05- 13.2			20.28- 26.4		20.2- 26.4	4A + 4A	_						
		20.28- 26.4		20.2- 26.4		20.28- 26.4		20.2- 26.4								
	eFlow4NB			eFlow6NB												
	10.1- 13.2		10.05- 13.2		10.0- 13.2		10.03- 13.2			A 1	1		7	5A/ 250V	7.5A/32V (eFlow4NB) 10A/32V (eFlow6NB)	730 (eFlow4NB) 910 (eFlow6NB)
Maximal13FE	10.1- 13.2		10.05- 13.2			20.19- 26.4		20.19- 26.4	4A + 6A			2				
		20.28- 26.4		20.2- 26.4	10.0- 13.2		10.03- 13.2									
		20.28- 26.4		20.2- 26.4		20.19- 26.4		20.19- 26.4								
	eFlow6NB			eFlow6NB												
	10.0- 13.2		10.03- 13.2		10.0- 13.2		10.03- 13.2			2	_	2	7	5A/ 250V	10A/32V	910
Maximal33FE	10.0- 13.2		10.03- 13.2			20.19- 26.4		20.19- 26.4	6A + 6A							
		20.19- 26.4		20.19- 26.4		20.19- 26.4		20.19- 26.4								
		eFlow6NB		eFlow102NB								10A/32V	910			
Maximal35FE	10.0- 13.2		10.03- 13.2		10.03- 13.2		10.03- 13.2		6A + 10A	2	_	2	7	5A/ 250V	(eFlow6NB) 15A/32V (eFlow102NB)	(eFlow6NB) 760 (eFlow102NB)
		20.19- 26.4		20.19- 26.4	10.03- 13.2		10.03- 13.2									
	eFlow6NB				eFlow104NB								5A/250V	10A/32V	910	
Maximal37FE	10.0- 13.2		10.03- 13.2			20.17- 26.4		20.28- 26.4	6A + 10A	2	_	2	8	(eFlow6NB) 6.3A/250V (eFlow104NB)	10A/32V (eFlow6NB) 15A/32V (eFlow104NB)	(eFlow6NB)
		20.19- 26.4		20.19- 26.4		20.17- 26.4		20.28- 26.4								(eFlow104NB)
	eFlow102NB			eFlow102NB			104 . 104 -	_				5A/	151/227			
Maximal55FE	10.03- 13.2		10.03- 13.2		10.03- 13.2		10.03- 13.2		10A + 10A 2	_	2	7	250V	15A/32V	760	
Maximal75FE		eFlow	102NB			eFlow	104NB		10A + 10A	2	_	2	8	5A/250V (eFlow102NB)	250V 15A/32V	760 (eFlow102NB)
	10.03- 13.2		10.03- 13.2			20.17- 26.4		20.28- 26.4						6.3A/250V (eFlow104NB)		700 (eFlow104NB)
		1	104NB				104NB		104 . 10					6.3A/		
Maximal77FE		20.17- 26.4		20.28- 26.4		20.17- 26.4		20.28- 26.4	10A + 10A	2	_	2	9	250V	15A/32V	700

Maximal Expandable Power Systems - 3 -

MaximalFE Installation Instructions:

Wiring methods shall be in accordance with the National Electrical Code/NFPA 70/ANSI, the Canadian Electric Code, Part I, Part II, and with all local codes and authorities having jurisdiction. Product is intended for indoor use only.

Power Supply Board Terminal Identification (pg. 5)
Power Supply Stand-by Battery Specifications (pg. 5)
Power Supply Board LED Diagnostics (pg. 6)
Power Supply Board Output Voltage Settings (pg. 6)

- 1. Mount unit in desired location. Mark and predrill holes in the wall to line up with the top three keyholes in the enclosure. Install three upper fasteners and screws in the wall with the screw heads protruding. Place the enclosure's upper keyholes over the three upper screws; level and secure. Mark the position of the lower three holes. Remove the enclosure. Drill the lower holes and install the three fasteners. Place the enclosure's upper keyholes over the three upper screws. Install the three lower screws and make sure to tighten all screws (*Enclosure Dimensions, pg. 9*).
- 2. Connect unswitched AC power (120VAC 60Hz) to terminals marked [L, N] (Fig. 2, pg. 7). Use 14 AWG or larger for all power connections. Secure green wire lead to earth ground. Keep power-limited wiring separate from non power-limited wiring (120VAC 60Hz Input, Battery Wires). Minimum 0.25" spacing must be provided. For Fire Alarm applications the outputs are "Special Applications" only, see list (refer to Appendix A, pg. 9). Keep power-limited wiring separate from non power-limited wiring. Minimum 0.25" spacing must be provided. CAUTION: Do not touch exposed metal parts. Shut branch circuit power before installing or servicing equipment. There are no user serviceable parts inside. Refer installation and servicing to qualified service personnel.
- 3. Select desired DC output voltage by setting SW1 to the appropriate position, (Maximal11FE, Maximal13FE, Maximal33FE, Maximal35FE and Maximal37FE) (Fig. 1a, pg. 6). Maximal55FE power supplies are factory set at 12VDC. Maximal77FE power supplies are factory set at 12VDC and 24VDC (Power Supply Board Stand-by Battery Specifications, pg. 5).
- 4. Measure output voltage before connecting devices. This helps avoiding potential damage.
- 5. Connect devices or Altronix sub-assembly modules to be powered to the terminals marked [- DC +] (Fig. 2, pg. 7). For auxiliary device connection, this output will not be affected by Low Power Disconnect or Fire Alarm Interface. Connect device to the terminals marked [+ AUX -] (Fig. 2, pg. 7). Refer to page 2 for non power-limited applications.
- 6. For Access Control applications batteries are optional. When batteries are not used, a loss of AC will result in the loss of output voltage. When the use of stand-by batteries is desired, they must be lead acid or gel type. Connect battery to the terminals marked [– BAT +] (Fig. 2, pg. 7). Use two (2) 12VDC batteries connected in series for 24VDC operation (battery leads included). Use batteries Casil CL1270 (12V/7AH), CL12120 (12V/12AH), CL12400 (12V/40AH), CL12650 (12V/65AH) batteries or UL recognized BAZR2 batteries of an appropriate rating.
- 7. Connect appropriate signaling notification devices to AC FAIL & BAT FAIL (Fig. 2, pg. 7) supervisory relay outputs.
- 8. To delay AC reporting for 2 hrs., set dip switch [AC Delay] to OFF position (*Fig. 2, pg. 7*). To delay AC reporting for 1 min., set dip switch [AC Delay] to ON position (*Fig. 2, pg. 7*). **Note:** Must be set to ON position for Burglar Alarm Applications.
- 9. To enable Fire Alarm Disconnect set dip switch [Shutdown] to ON position. (Fig. 2, pg. 7). To disable Fire Alarm Disconnect set dip switch [Shutdown] to OFF position. (Fig. 2, pg. 7).
- 10. Trigger terminals are end of a line resistor supervised (10k ohms). Opening or shorting trigger terminals will cause [DC] output to shutdown (*Fig. 2, pg. 7*).
- 11. Place a jumper for non-latching FACP. A momentary short on these terminals resets FACP latching [Trigger EOL Shutdown] (Fig. 2, pg. 7).
- 12. For Access Control Applications: mount UL Listed tamper switch (Sentrol model 3012 or equivalent) at the top of the enclosure. Slide tamper switch bracket onto the edge or the enclosure approx. 2" from the right side (*Fig. 2a, pg. 7*). Connect tamper switch wiring to the Access Control Panel input or the appropriate UL Listed reporting device.
- 13. Please ensure that the cover is secured with the provided key lock.

Maintenance:

Unit should be tested at least once a year for the proper operation as follows:

Output Voltage Test: Under normal load conditions the DC output voltage should be checked for proper voltage level (MaximalFE Configuration Chart, pg. 3).

Battery Test: Under normal load conditions check that the battery is fully charged, check specified voltage at the battery terminals and at the board terminals marked [– BAT +] to ensure that there is no break in the battery connection wires. **Note:** Maximum charge current 1.54 amp.

Expected battery life is 5 years; however, it is recommended to change batteries within 4 years or less if necessary.

- 4 - Maximal Expandable Power Systems

Power Supply Board Terminal Identification:

Terminal Legend	Function/Description				
L, G, N	Connect 120VAC 60Hz to these terminals: L to hot, N to neutral. Do not use the [G] terminal				
+ DC -	Refer to MaximalFE Series Configuration Chart, pg. 3.				
Trigger EOL Supervised	Fire Alarm Interface trigger input from a short or FACP. Trigger inputs can be normally open, normally closed from an FACP output circuit (power-limited input).				
NO, GND RESET	FACP interface latching or non-latching (power-limited).				
+ AUX –	Auxiliary Power-Limited output rated @ 1 amp (unswitched) (power-limited output).				
AC Fail NC, C, NO	Indicates loss of AC power, e.g. connect to audible device or alarm panel. Relay normally energized when AC power is present. Contact rating 1 amp @ 30VDC (power-limited).				
Bat Fail NC, C, NO Indicates low battery condition, e.g. connect to alarm panel. Relay normally energized when is present. Contact rating 1 amp @ 30VDC. A removed battery is reported within 5 minutes. Battery reconnection is reported within 1 minute (power-limited).					
-BAT +	Stand-by battery connections. Maximum charge current 1.54 amp (non power-limited).				

Power Supply Board Stand-by Battery Specifications

eFlow4NB:

Battery	Access Control Applications Stand-by
7AH	30 Mins./4 amp*
12AH	35 Mins./4 amp*
40AH	Over 4 Hours/4 amp*
65AH	Over 4 Hours/4 amp*

eFlow6NB:

Battery	Access Control Applications Stand-by
7AH	10 Mins./6 amp
12AH	30 Mins./6 amp*
40AH	Over 4 Hours/6 amp*
65AH	Over 4 Hours/6 amp*

eFlow102NB:

Battery	Access Control Applications Stand-by
7AH	5 Mins./10 amp
12AH	30 Mins./10 amp*
40AH	Over 2 Hours/10 amp*
65AH	Over 4 Hours/10 amp*

eFlow104NB:

Battery	Access Control Applications Stand-by
7AH	5 Mins./10 amp
12AH	30 Mins./10 amp*
40AH	Over 2 Hours/10 amp*
65AH	Over 4 Hours/10 amp*

^{*}Only these configurations can be utilized in ULC-S319 installations.


Maximal Expandable Power Systems - 5 -

Power Supply Board LED Diagnostics:


Green (DC)	Green (AC/AC1)	Power Supply Status
ON	ON	Normal operating condition.
ON	OFF	Loss of AC. Stand-by battery supplying power.
OFF	ON	No DC output.
OFF	OFF	Loss of AC. Discharged or no stand-by battery. No DC output.

Power Supply Board Output Voltage Settings:

Fig. 1 - eFlow4NB / eFlow6NB Power Supply Board



- 6 - Maximal Expandable Power Systems



Keep power-limited wiring separate from non power-limited. Use minimum 0.25" spacing.

Up to four (4) 12AH Rechargeable batteries are the largest batteries that can fit in this enclosure.

A UL Listed external battery enclosure must be used if using the 40AH or 65AH batteries.

Maximal Expandable Power Systems - 7 -

NEC Power-Limited Wiring Requirements:

External Jacketed Shield

Pull back

external jacketed

shield approx. 1/2".

Wire


Solid Copper

Conductors

Power-limited and non power-limited circuit wiring must remain separated in the cabinet. All power-limited circuit wiring must remain at least 0.25" away from any non power-limited circuit wiring. Furthermore, all power-limited circuit wiring and non power-limited circuit wiring must enter and exit the cabinet through different conduits. One such example of this is shown below. Your specific application may require different conduit knockouts to be used. Any conduit knockouts may be used. For power-limited applications use of conduit is optional. All field wiring connections must be made employing suitable gauge CM or FPL jacketed wire (or equivalent substitute).

Optional UL Listed battery enclosure must be mounted adjacent to the power supply via Class 1 wiring methods. For Canadian installations use shielded wiring for all connections.

Note: Refer to wire handling drawing below for the proper way to install the CM or FPL jacketed wire (Fig. 3a).



- 8 - Maximal Expandable Power Systems


Maximal77FE

*Power-limited for Maximal11FE.

Maximal13FE has one power-limited board
(eFlow4NB) and one non power-limited (eFlow6NB).

Non power-limited for Maximal33FE, Maximal35FE,
Maximal37FE, Maximal55FE, Maximal75FE,

Enclosure Dimensions (H x W x D approximate): 26" x 19" x 6.25" (660.4mm x 482.6mm x 158.75mm)



Maximal Expandable Power Systems - 9 -

Notes:

Maximal Expandable Power Systems - 10 -

Notes:

- 11 - Maximal Expandable Power Systems

Notes:

