## Overview

Control Concord panels with either the ATP-1000 Alphanumeric programmable touchpad or the FTP-1000 Fixed English touchpad. Messages are displayed in a large and easy-to-see LCD window, and emergency keys are highlighted on the touchpad for safety.

Both the ATP-1000 and the FTP-1000 touchpads allow control of Concord Express, Concord 3, Concord Ultra, and Concord 4 products. The large display provides easy-to-read messages that indicate the current status of the system. In addition, the ATP-1000 touchpad can be used for installer/user programming of the Concord control panels and has the added capability of displaying customized zone naming text.

Both touchpads include police, fire, and auxiliary panic buttons that can be activated any time. A built-in speaker provides alarm, status, and buttonpress sounds. The swing-down door reveals a label with basic system operating commands—or remove the door by simply opening it past its stop point. The door can be reattached later if desired. Emergency keys are highlighted on the keypad for safety and ease of use. All keys are backlit to insure error free operation—even in a dark room.

## Standard Features

- Large easy-to-read display
- Improved backlighting of display and keys for better visibility
- Stand-alone panic keys
- Stand-alone arming keys
- Traditional design to blend with any décor
- Easy to install

# ATP-1000 and FTP-1000

## Touchpads for use with Concord™ Systems



ATP-1000

FTP-1000

## Specifications

| | |
|---|---|
| Compatibility | Concord 3, Concord Express, Concord Ultra, Concord 4 |
| Electrical | Voltage: 12 VDC nominal<br>Current: 75 mA (FTP-1000)<br>Current: 60mA typical, 110mA in alarm (ATP-1000) |
| Environmental | Operating temperature: 32 to 120°F (0 to 49°C)<br>Storage temperature: -30 to 140°F (-34 to 60°C)<br>Relative humidity: 85% max., noncondensing |
| Physical | Dimensions (LxWxD): 5.0 x 4.50 x 0.75 in. (127 x 114 x 19 mm) |
| Regulatory | UL/cUL listings: UL (985, 1023, 1610)<br>cUL (C1023 - 1974, S545 - M89) |

*For cUL listed applications, the unit shall be installed in accordance with Part 1 of the Canadian Electrical Code.*

## Ordering Information

| | |
|---|---|
| 600-1020 | Fixed English touchpad |
| 60-983 | Alphanumeric touchpad |